



COORDINATE LINE DEACTIVATION WITH
ENGLEWOOD WATER DISTRICT

ADJUST PIPE DETAIL FOR WATER MAINS OR FORCEMAINS

N.T.S.

- * UTILITY CONFLICTS WILL BE RESOLVED SO THAT WATER MAINS CROSS OVER OR THROUGH PROPOSED DRAINAGE CULVERTS.
- * THRUST BLOCKS ARE NOT AN ACCEPTABLE FORM OF JOINT RESTRAINT FOR THIS AREA.
- * WHERE A MINIMUM COVER OF 18" CAN NOT BE MAINTAINED THE CROSSING WILL BE REVIEWED CASE-BY-CASE TO ADDRESS CORRECTIVE ACTION BASIS.