



BACKFILL TRENCH W/SUITABLE MATERIAL IN LAYERS NOT TO EXCEED 12" TO AN AVG. DENSITY NOT LESS THAN 100% OF MAX. DENSITY AS DETERMINED BY AASHO T99.

TRENCH DETAIL
N.T.S.

- NOTE: 1) EXISTING SURFACE AND BASE TO BE CUT SQUARE WITH CONCRETE SAW
2) NEW PIPE TO BE INSTALLED 30" DEEP MAXIMUM