


- * UTILITY CONFLICTS WILL BE RESOLVED SO THAT WATER MAINS CROSS OVER OR THROUGH PROPOSED DRAINAGE CULVERTS.
- * THRUST BLOCKS ARE NOT AN ACCEPTABLE FORM OF JOINT RESTRAINT FOR THIS AREA.
- * WHERE A MINIMUM COVER OF 18" CAN NOT BE MAINTAINED THE CROSSING WILL BE REVIEWED CASE-BY-CASE TO ADDRESS CORRECTIVE ACTION BASIS.

LAST REVISION	NOV. 2017
CHECKED	KRL
APPROVED	PZ

**ADJUST PIPE DETAIL FOR
WATER MAINS OR FORCEMAINS**



ENGLEWOOD WATER DISTRICT
201 SELMA AVENUE
ENGLEWOOD, FLORIDA 34223