


BACKFILL TRENCH W/SUITABLE MATERIAL IN LAYERS NOT TO EXCEED 12" TO AN AVG. DENSITY NOT LESS THAN 100% OF MAX. DENSITY AS DETERMINED BY AASHO T99.

NOTES:

1. EXISTING SURFACE AND BASE TO BE CUT SQUARE WITH CONCRETE SAW
2. NEW PIPE TO BE INSTALLED 30" DEEP MINIMUM COVER

|               |           |
|---------------|-----------|
| LAST REVISION | NOV. 2017 |
| CHECKED       | KRL       |
| APPROVED      | PZ        |

**TRENCH DETAIL**



**ENGLEWOOD WATER DISTRICT**  
 201 SELMA AVENUE  
 ENGLEWOOD, FLORIDA 34223