



ENGLEWOOD WATER DISTRICT

201 Selma Ave
Englewood, FL 34223
(941) 474-3217

To: Prospective Bidders
Date: December 28, 2017
Re: **Addendum #2** to RFB 2017-107 Generator Maintenance & Repair Services

Bidders are notified that this Addendum will be made part of the bid documents. The intent of the Addendum is to add to, modify, or clarify the documents. Should any of these items have an effect on price, such changes shall be included in the bid price. These items have the same force and effect as if contained in the original documents.

ITEM 1 BID EXTENSION

Please note that the bid opening has been extended to **2:30 p.m. (EST), January 17, 2018**. Sealed bids need to be delivered by **2:15 p.m. (EST) on the same day** of the bid opening.

ITEM 2 TECHNICAL SPECIFICATIONS – RESPONSE TIME

Please add the following paragraph to the **RESPONSE TIME** section on **page 16** of the bid package:

It is critical that the successful bidder responds to any emergency calls to repair the generator connected to high service pumps at the lime plant (#18 on the Attachment 1, EWD Generator List) in less than, but not to exceed 2 hours from the time the call is placed. Failure to respond within the stipulated time will likely result in termination of the award.

Bidders are required to acknowledge receipt of this addendum in their bid forms.

B. L. Wheaton

**Bee Ling Wheaton,
Purchasing Specialist**